

11/2019Standalone/Portable/Ducted11041903Commercial/Remedeation

2008 B (1-4) GAP™

© 2019 Genesis Air, Inc. Lubbock, Texas U.S.A.

Stand Alone Photocatalytic Oxidation Technology

Installation and Maintenance Instructions for All 2008 PCP Compounds

General

The Genesis Air 2008B is a stand-alone unit used to reduce the levels of Volatile Organic Compounds (VOC's) and viable airborne biological contaminants. The unit may be ducted in for permanent installations or utilized as a roll-around "point-of-use" air purifier. The 2008B uses one to four Genesis Air 2021 PCP Compound panels. For example, a 2008B3 would have three panels installed. The Genesis Air 2008B is suitable for spaces up to 22000 ft3. For recommended unit configurations, consult engineering at Genesis Air Inc. All Genesis Air products incorporate 3-step GAP technology: MERV Filtration, UVGI Lamps and Photocatalysis

WARNING



Electric shock hazard Can cause injury of death Disconnect all remote electrical power supplies before servicing. Access panels must be in place during operation.

WARNING!

Mercury Hazard. Do not Break

Each UVC lamp contains a small amount of Mercury. In case of breakage use proper disposal techniques on page 5-6.

Shipping and Packing List

1 - 2008 B

Standard Features: Variable Speed Control Casters, lifting handles and powder coated mock rock. Options:

Scaleable up to 4 PCP Panels Particulate Adapter

Nomenclature

XXXX

2440 = 24" Height / 40" Length

Packaged Unit Description

- 56 = Power Unit Compound (Line Voltage Input)
- 57 = Center Section Compound
- 58 = End Section Compound

WARNING



UVC light hazard. UVC light can cause temporary or permanent loss of vision and sunburn. Take proper precautions to protect eyes and skin from direct exposure.

WARNING!

Improper installation, adjustment, alteration, service or maintenance can cause property damage, personal injury or loss of life. Installation and service must be performed by a qualified installer or service agency.

Special Features

Air Speed: 2280 fpm Variable Speed Control Volts: 120 60 Hertz Amps: 6.5 / 7.6 / 8.7 / 9.8 Weight: 163 / 174 / 185 / 197 UVGI life cycle: 12,000 operation hours Filtration: Merv 13 (Supplied) to HEPA Installation: Portable and wall or ceiling mount.

Safety Certifications

UL Classified UL File No. E326567 FIFRA....EPA EST No. 877447--TX--001 OSHPOD - Pending



UL REQUIREMENTS

- 105°C minimum supply connections
- For catalyst marked "XXXX", 50°C/122°F maximum ambient temperature. For those marked "XXXX-E", 80°C/176°F maximum ambient temperature.
- Suitable for air-handling units
- Access above ceiling may be required
- The health aspects associated with the use of this product and its ability to aid in disinfection of environment air have not been investigated by UL.
- Use only First Light type T5 lamps specified by the PCP Compound.
- **Warning:** The electrical supply circuit connected to this UV appliance must be routed through an electrical interlock switch placed on the HVAC system duct access panels and doors to prevent accidental UV exposure when servicing the air ducts or equipment.
- **Caution:** Equipment Damage Hazard. Ultraviolet light can cause color shift or surface degradation and sometimes structural degradation of non-metallic components. Select mounting location that prevents exposure to plastic flexible duct components, polyurethane foam insulation material, rubber hoses, wiring insulation, filtration media, etc. If mounting options are limited, items above should be protected with ultraviolet resistant material such as aluminum foil, aluminum duct tape, or metallic shields.

Dimensional Data







UVGI Lamps

Genesis Air lamps do not produce ozone! The lamps provide a minimum intensity of 775 microwatts/cm2 (5 milliwatts per square inch) at 10.77 centimeters (4.24") to activate the catalyst effectively. To maintain tested performance, lamps may not be substituted with another manufacturer's products. These lamps provide UV-C wavelengths @ 254 nm. All lamps must be replaced every 16 months (12000 hrs) of continuous use to maintain intensity requirements. Genesis Air lamps contain trace amounts of mercury, encapsulated within the lamp and therefore reducing risk to the consumer or ecosphere.

LAMP SERVICE

ALL UNITS MUST BE POWERED DOWN BEFORE REPLACING LAMPS.

ALL MAINTENANCE PERSONNEL MUST WEAR UV PROTECTIVE SAFETY GLASSES. ALL EX-POSED SKIN MUST BE PROTECTED BY UV RESISTANT CLOTHING.

<u>GENERAL</u>

To operate effectively, the lamps must be replaced every 16 months, as the intensity of the lamps decreases over time. The catalyst must be energized by the lamps to create the field of hydroxyl radicals that is required to remove VOC's and biologicals. Without the proper lamp output, VOC's and biologicals will not be reduced!

INSPECTION

- To inspect the lamps, the lamps must be powered. Wear UV resistant face shields and personal protective equipment!
- On all units, inspect the green mounting sleeves (Green Sleeve) on the unit. If the lamps are lit, they will emit a bright green glow.
- If any lamp is unlit, power off the unit. Unplug the wiring harness from the lamp and plug the harness onto a lamp known to be operational. Power on the unit. If the new lamp does not light, the problem could be in the ballast. Keep in mind that the safety switch will not allow the lamps to light if the filter grille door is open. THIS IS NOT CONSIDERED POWERING DOWN THE UNIT! A pressure-kill box is an accessory that provides electricians with single point to wire to and two safety devices. One will kill power to the lamps when pressure drops below a set point, and the other kills power to the lamps when an access door is opened. A momentary safety bypass, also included, will allow power to bypass the safeties to power the lamps for visual inspection.
- If the new lamp lights, the old lamp is faulty. Proceed to removal.

<u>Removal</u>

- Power the Genesis Air unit down using the kill switch or breaker to unit.
- Caution! The lamps may be hot! Wear gloves to protect hands.
- Unplug the harness from the faulty lamp.
- Unscrew the GreenSleeve from the base of the unit and remove lamp with sleeve from the unit.

Disposal

Mercury produces a hazardous waste. Every form of it is toxic and yet mercury is an essential element in millions of fluorescent lamps throughout the United States and millions more throughout the world. State and federal regulatory agencies are working to reduce mercury releases to the environment. Since January 1, 2000, the United States Environmental Protection Agency (USEPA) has allowed for spent lamps to be managed as Universal Wastes. The Universal Waste Rules (UWR) are designed in part to simplify the management of mercury-containing wastes including spent fluorescent lamps. The Rules are also intended to encourage recycling, thereby reducing mercury emissions to the environment.

As an alternative to managing lamps as universal wastes, a facility may elect to manage its spent lamps as hazardous wastes. Hazardous waste rules - like the universal waste rules - are promulgated under the federal Resource Conservation Recovery Act (RCRA) and state laws equivalent to RCRA. RCRA regulates hazardous wastes "from the cradle to the grave." RCRA Subtitle C requires a waste generator to properly identify, treat, store, transport and dispose of hazardous wastes. The USEPA oversees the RCRA program but has delegated to the States the responsibility for the day-to-day management of the program.

List of Lamp Recycling Facilities for the US

AERC Recycling Solutions - Hayward, CA AERC Recycling Solutions - West Melbourne, FL AERC Recycling Solutions - Allentown, PA Universal Recycling Technologies - Dover, NH Universal Recycling Technologies - Clackamas, OR Veolia ES - Port Washington, WI Universal Recycling Technologies - Fort Worth, TX

Installation

- Installation is the reverse of removal
- Push socket onto lamp pins until socket butts against lamp



Catalyst

- ALL UNITS MUST BE POWERED DOWN BEFORE SERVICING.
- ALL MAINTENANCE PERSONNEL MUST WEAR UV PROTECTIVE FACE SHIELDS. ALL EX-POSED SKIN MUST BE PROTECTED BY UV RESISTANT CLOTHING.

General

Genesis Air recommends catalyst replacement every fifteen years to provide an efficient system. As debris and contaminants accumulate on the catalyst, the effectiveness of the catalyst is decreased. The catalyst must be inspected periodically for buildup of particulate.

Inspection

- Power down the unit undergoing inspection. ٠
- Locate the Genesis Air PCP Compound in guestion.
- Visually inspect each catalyst wearing UV protective clothing and face shields. If the catalyst ap-٠ pears clean and free of particulate, proceed to the next unit. If the catalyst cannot be seen, continue to next item.
- Remove some of the lamps. With a flashlight, visually inspect the catalyst through the holes.
- If the catalyst appears clean and free of particulate, replace lamps and proceed to the next AHU. Otherwise, proceed to removal.

Universal Recycling Technologies -Janesville, WI

- Veolia ES Phoenix. AZ
- Veolia ES Tallahassee, FL
- Veolia ES S toughton, MA

Cleaning

- If the catalyst needs cleaning from light to moderate dust build up. Disconnect power, use a hand sprayer with water only and rinse the catalyst. Avoid heavy concentrations of spray on ballast tray.
- If catalyst is soiled by resin (E.T.S.) or grease. Remove and spray catalyst liberally with Nu-Calgon CalClean, Special HD or other suitable coil cleaner on catalyst only. Allow to sit 15 minutes, then wash off with pump up water spray bottle. Do not remove installation reminders!
- Allow catalyst to lightly dry before returning to service.

Removal

- If catalyst will be cleaned and reused, keep track of which area the catalyst came from so they will be returned from where they were removed. This will prevent installation problems. Write or draw on the metal frames to help with installation.
- Remove all lamps from the catalyst.
- Remove from the rack. You may need to contact the installer.

the catalyst substrate

WARNING!

High pressure spray will damage the windowing in

Power

Ballasts are matched to the specific length of lamp. To maintain tested performance, ballasts may not be substituted with another manufacturer's products. The ballasts must be specified either 120v or 240v, 60 Hz: contact the factory for other voltage/frequency requirements. The ballast operating temperature range is -20°F to 158°F.

Safety

UVGI

Ultraviolet germicidal irradiation (UVGI) used for the activation of the PCO Catalyst. The residual light can be used for irradiating the evap. coil surface for biological microorganisms but presents a variety of potential health hazards to humans as well, including eye damage, skin burns, and even has the potential to cause skin cancer. Because germicidal UV rays are invisible to the eye, humans may be subject to hazardous doses of UV long before they realize it. There is no Occupational Safety and Health Administration (OSHA) standard for exposure to ultraviolet light. UV can be associated with adverse health effects depending on duration of exposure and the wavelength. The adverse health effects that may occur are erythema (sunburn), photokeratitis (a feeling of sand in the eyes), skin cancer, melanoma, cataracts, and retinal burns. Since maintenance personnel may be accidentally exposed to the radiation from UV lamps while in the course of their duties, it is essential that all UV sources and facilities be adequately labeled to instruct such personnel of the danger of exposure (in some cases, these warnings should be in both English and Spanish; Danger – Ultraviolet Radiation > Peligro -- Radiación Ultravioleta). Ideally, all activated UV sources should either be attended by knowledgeable personnel at all times.

- DISCONNECT ALL POWER TO SYSTEM BEFORE SERVICING
- PROPER SAFETY GLASSES OR FACE SHIELD MUST BE WORN WHEN INSPECTING OPERATIONAL LAMPS
- PROPER CLOTHING MUST BE WORN TO COVER EXPOSED SKIN
- ALL ENTRY DOORS THAT HAVE DIRECT SITE TO THE CATALYST MUST HAVE SAFETY LIMIT SWITCHES INSTALLED TO SHUT OFF LAMPS DURING ENTRY INTO AHU.
- ALL VIEWING WINDOWS OR PORTS MUST BE HAVE UV RESISTANT AND FILTERING PROPERTIES. NO GLASS IS PERMITTED
- Harden all plastic in direct site of the catalyst (Foil Tape)
- All field wiring when possible should be in metal conduit or of a UV resistant type.
- In case of lamp breakage the lamps are incased in a Teflon coating to reduce any chance of glass or mercury of entering the air stream.

Installation

Installation Examples



Standalone bar application



Ducted office application

WARNING! Do not use silicone to seal catalyst racks to floor or ceiling. The presence of silicone in UV light will pol- lute the catalyst.	WARNING! Sharp edges hazard. Equipment sharp edges can cause injuries Use protective gloves when grasping equipment edges.
WARNING!	WARNING!
Unpacking required	Lamps contain Mercury.
Remove all protective packing material from the box	Ingestion or contact with mercury or mercury vapor
before removal of catalyst panel. All packing material	is hazardous to your health.
should be discarded properly.	Take care when handling lamps. If broken, avoid
	contact with mercury

Electrical Diagram



Installation

This unit is designed to be installed as a roll-around, portable unit or installed permanently suspended from the roof truss, beams or ceiling. Installation must be completed by competent personnel. Genesis Air, Inc. assumes no liability for damages or injuries sustained from installations done by other than qualified Genesis Air technicians.

- If the unit is to be suspended, remove the casters if included. Also, if the unit is to be suspended upside-down for accessibility, the lid should include a pivot hinge from the factory.
- Determine a location for the 2008B unit, above the ceiling for drop-tile or in free air for warehouse, etc. Consider where your returns and supplies will be located, with the B unit in between, clearance from permanent ductwork, beams, lights, sprinklers or other above-ceiling fixtures. Also, the B must be suspended from something, so make sure there is truss work above. Finally, the B unit is very large, a 24" x 48" opening (minimum) must be made in the ceiling grid. Find a location that would make this easy.
- If your unit has no Unistrut, attach Unistrut where the casters were. The Unistrut should extend 4" on either side of the B unit and be able to support 250 lb.
- If there is no place to bolt all-thread rods on the roof trusses where the B will hang, Unistrut must also be attached to the roof trusses. 3/8" All-thread can be bolted into the unistrut and left to hang.
- Using a material lift, lift the B into position. Run the all-thread thru the Unistrut and bolt down, ensuring the unit is level and not twisted.
- Choose a location for the return/filter section close to the source of odors or biologicals. The filter section(s) should be installed in this general vicinity.
- Using a lift, ladder or scaffolding, remove a ceiling tile above the source next to the return grille.
 Use judgment here: there needs to be clearance from permanent ductwork, beams, lights, sprinklers or other above-ceiling fixtures.
- Lift the filter section up above the ceiling grid; you may have to angle the unit thru. Once the unit is above the grid, set the unit onto the grid carefully. You should see the 4" particulate filter from the ground.
- Use the same guidelines to add more returns and supply(s).
- Attach ductwork. Note: If ductwork is altered, installer must insure that no leakage of UV light occurs as a result of ductwork modifications!
- Airflow is from the filter(s) to the filter side of the B unit, Through the B to the fan side of the B unit, then out to the supply(s).
- Power up the B unit.
- Clean up your mess, and replace ceiling tiles.



LIMITED WARRANTY

FAILURE TO MAINTAIN YOUR EQUIPMENT WILL VOID THIS WARRANTY

Your GENESIS AIR^{**} purification system is expressly warranted from the date of installation to be free from manufacturing defects for the coverage period stated below. Defective parts must be returned no later than thirty (30) days after the failure by you to the installing contractor together with the GENESIS AIR™ purification system's model number, serial number, and documented installation date of the GENESIS AIR[™] purification system.

ONE (1) YEAR COVERAGE -- RESIDENTIAL AND COMMERCIAL APPLICATIONS

The covered equipment and covered components are warranted by GENESIS AIR for a period of ONE (1) year from the date of the original unit installation, when installed in a residential or commercial application. If during this period, a covered component fails because of a manufacturing defect, GENESIS AIR will provide a free replacement part. You must pay shipping charges and all other costs of warranty service. GENESIS AIR will not pay labor involved in diagnostic calls or in removing, repairing, servicing or replacing parts. Such costs may be covered by a separate warranty provided by the installer. NOTE - If the date of original installation cannot be verified, the warranty period will be deemed to begin six (6) months after the date of manufacture.

EXCLUDED COMPONENTS

The following components are not covered by this warranty: the UVCGI lamps or the pleated photo catalytic material. These are replacement items, which must be replaced as stated in the Maintenance section of the installation instructions to ensure effective operation.

REPAIRS

All repairs of covered components must be made with authorized service parts by a qualified service dealer or contractor. Labor charges are not covered by this warranty.

WARRANTY LIMITATIONS

This warranty will be voided if the covered equipment is removed from the original installation site. This warranty does not cover damage or defect resulting from:

1 - Flood, wind, fire, lightning, or installation and operation in a corrosive atmosphere (chlorine, fluorine, salt, recycled waste water, urine, fertilizers, or other damaging chemicals).

2 - Accident, or neglect or unreasonable use or operation of the equipment, including operation of electrical equipment at voltages other than the range specified on the unit nameplate (includes damages caused by brownouts).

3 - Modification, change or alteration of the equipment, except as directed by GENESIS AIR.

4 - Operation with system components (indoor unit and control devices), which do not match, or meet the specifications recommended by GENESIS AIR.

5- Operation with system components (indoor unit and control devices), which exceed operational temperature range of; -20 F to 122F. 6-Warning: The panels are self cleaning when lamps are on and replaced every 16 months. Failure to replace lamps within 16 months or power lamps after install on an operational unit will void all panel warranties.

THIS WARRANTY SHALL NOT OBLIGATE THE MANUFACTURER FOR ANY LABOR COSTS AND SHALL NOT APPLY TO DEFECTS IN WORKMANSHIP OR MATERIALS FURNISHED BY THE INSTALLING CONTRACTOR AS CONTRASTED TO DEFECTS IN THE GENESIS AIR** PURIFICATION SYSTEM ITSELF. IMPLIED WARRANTIES OF MERCHANTABILITY OR FIT-NESS FOR A PARTICULAR PURPOSE SHALL BE LIMITED IN DURATION TO THE AFORESAID COVERAGE PERIOD. THE MANUFACTURER'S LIABILITY FOR INCIDENTAL OR CONSEQUENTIAL DAMAGES, OTHER THAN DAMAGES FOR PER-SONAL INJURIES, RESULTING FROM ANY BREACH OF THE AFORESAID IMPLIED WARRANTIES OR THE ABOVE LIM-ITED WARRANTY IS EXPRESSLY EXCLUDED. THIS LIMITED WARRANTY IS VOID IF DEFECT(S) RESULT FROM FAILURE TO HAVE THIS UNIT INSTALLED BY A QUALIFIED HEATING AND AIR CONDITIONING CONTRACTOR. IF THE LIMITED WARRANTY IS VOID DUE TO FAILURE TO USE A QUALIFIED CONTRACTOR, ALL DISCLAIMERS OF IMPLIED WARRAN-TIES SHALL BE EFFECTIVE UPON INSTALLATION.

Some states do not allow limitations on how long an implied warranty lasts or the exclusion or limitation of incidental or consequential damages, so the above exclusion or limitations may not apply to you. This warranty gives you specific legal rights and you may also have other rights, which vary from state to state.

To register your new GENESIS AIR™ Purification System, PLEASE CUT ON DOTTED LINE AND RETURN THE

REGISTRATION FORM TO THE ADDRESS NOTED BELOW.

Customer Name: Address: City: State/Province: Zip/Postal Code:_____

Home Phone: E-mail:

Installing Contractor: Phone:_____

Date of installation: Model Number: ______ Serial Number:



Please send this completed form to: GENESIS AIR™ GENESIS AIR, INC. 5202 CR 7350, SUITE D LUBBOCK, TX 79424